

**NEVADA DIVISION OF ENVIRONMENTAL PROTECTION
FACT SHEET**

(Pursuant to NAC 445A.236)

Permittee: Conoco Phillips Company
1230 W Washington Ste 212
Tempe AZ 85281

Permit No.: NV0023086

Facility: Union 76 Service Station No. 5558
3798 E Desert Inn Rd
(NW corner of intersection of E Desert Inn Rd and Sandhill Rd)
Clark County
Latitude: 36° 07' 48" North
Longitude: 115° 05' 28" West
T21S R62E S16

General: Union 76 # 5558 is a self service gas station with groundwater contamination due to a leaking underground storage tank system. Extraction wells feed an air stripper that discharges to Flamingo Wash via the adjacent storm drain on E Desert Inn Rd. Average discharge flow is approximately 3 gpm.

Receiving Water Characteristics: Flamingo Wash is tributary to Las Vegas Wash, and the standards at the nearest downstream control point, "Las Vegas Wash at Telephone Line Road", NAC 445A.199, apply. From the control point, the TDS standard is 1900 mg/l and the total inorganic nitrogen standard is 20 mg/l. In addition, Total Maximum Daily Loads (TMDLs) for Las Vegas Wash have been established for phosphorus and ammonia.

Rational for Permit Requirements: Please see Table I.A.1 below. The flow limit has been set at the Permittee's request and is within the design capacity of the air stripper. The limits for benzene, toluene, xylene, ethylbenzene, MTBE (methyl tert-butyl ether), and TPH (total petroleum hydrocarbons) have been set at levels previously established by the Division for general use in discharge permits. The total inorganic nitrogen limit is the water quality standard for Las Vegas Wash. The rest of the parameters; ammonia, total phosphorus, total dissolved solids (TDS), pH, and volatile organic compounds (VOCs) are subject to monitoring requirements without concentration limits. Ammonia and total phosphorus are included due to the existence of the TMDL, TDS in response to long standing salinity issues in the Colorado River, pH as an indicator of extreme conditions, and the annual influent VOC and full range TPH scans as a check on any changes in plume characteristics.

Nevada Division of Environmental Protection
Fact Sheet

Union 76 # 5558, 3798 E Desert Inn Rd, Clark County

NV0023086

Page 2 of 3

Table I.A.1

Parameter	Discharge Limitations		Monitoring Requirements		
	30 Day Avg	Daily Maximum	Location	Frequency	Sample Type
Flow, gpm	10 gpm	-	effluent	continuous	meter
Benzene, µg/l	-	5	effluent	monthly	discrete
Toluene, µg/l	-	100	effluent	monthly	discrete
Ethylbenzene, µg/l	-	100	effluent	monthly	discrete
Total Xylenes, µg/l	-	200	effluent	monthly	discrete
Methyl tert-butyl ether, µg/l	-	20	effluent	monthly	discrete
TPH ¹ , mg/l	-	1	effluent	monthly	discrete
Total Inorganic Nitrogen, mg/l	-	20	effluent	quarterly	discrete
Ammonia as Nitrogen, mg/l	-	monitor & report	effluent	quarterly	discrete
Total Phosphorus, mg/l	-	monitor & report	effluent	quarterly	discrete
Total Dissolved Solids, mg/l	-	monitor & report	effluent	quarterly	discrete
pH, standard units	-	monitor & report	effluent	quarterly	discrete
TPH ² mg/l	-	monitor & report	influent	annual ⁴	discrete
VOCs ³ , µg/l	-	monitor & report	influent	annual ⁴	discrete

Notes:

1. Total petroleum hydrocarbon, purgable range
2. Total petroleum hydrocarbons, purgable + extractable ranges
3. Volatile organic compounds by EPA Method 8260, report all parameters.
4. Annual samples shall be collected in the fourth quarter.

Schedule of Compliance: The facility is required to meet the effluent limits upon issuance of the permit.

Procedures for Public Comment: Notice of the Division's intent to renew discharge permit NV0023086, authorizing a groundwater remediation discharge to the storm drain at Union 76 # 5558 at 3798 E Desert Inn Rd, is being sent to the **Las Vegas Review Journal** for publication. The notice is being mailed to interested persons on our mailing list. Anyone wishing to comment on the proposed permit must submit written comments to the Division within (30) days of the publication date. The comment period can be extended at the discretion of the Administrator. The deadline for receipt of all written comments is Thursday March 10, 2005 by 5:00 pm. Comments received after the deadline will be accepted if postmarked on that date or before.

A public hearing on the proposed determination can be requested by the applicant, any affected state or interstate agency, the Regional Administrator, or

Nevada Division of Environmental Protection
Fact Sheet

Union 76 # 5558, 3798 E Desert Inn Rd, Clark County

NV0023086

Page 3 of 3

any interested agency, person, or group of persons. The request must be filed within the comment period and indicate the interest of the person filing the request and the reasons why a hearing is warranted. Public hearings granted by the Division are conducted in accordance with NAC 445A.238.

The final determination of the Division may be appealed to the State Environmental Commission pursuant to NRS 445A.605.

Proposed Determination: The Division has made the tentative determination to renew the proposed discharge permit for a five year term.

Prepared by: Robert J. Saunders
 Staff Engineer
 Bureau of Water Pollution Control
 January 31, 2005